



CSI: DIVISION: 22 00 00—PLUMBING
Section: 22 40 00—Plumbing Fixtures
Section: 22 09 00—Instrumentation and Control for Plumbing

Product certification system:

The ICC-ES product certification system includes testing samples taken from the market or supplier's stock, or a combination of both, to verify compliance with applicable codes and standards. The system also involves factory inspections, and assessment and surveillance of the supplier's quality system

Product: Flushometer-Valve for Water Closets

Listee: F.V. - Area Andina S.A.
Km 25 Autopista Los Chillos Vía Sangolquí - Amaguaña
Sangolquí / Pichincha / Ecuador
www.fvandina.com

Compliance with the following standards:

EPA WaterSense Specification for Flushometer-Valve Water Closets (Version 1.0)

Identification:

Each fixture component must be permanently and legibly marked with the manufacturer's name or registered trademark and the date of manufacture. Flushometers shall be permanently and visibly marked with the A line and the letters "CL" * to indicate the critical level and the water consumption in GPF and LPF and the EPA WaterSense logo and the ICC-ES PMG listing mark. All packaging must be marked with the manufacturer's name or registered trademark; or in case of private labeling, the name of the customer for whom the fixture was manufactured. Packaging for flushometers shall be marked with the model number water consumption in GPF and LPF.

Installation:

Flushometers are to be installed in accordance with the manufacturer's instructions and the applicable code.

Models:

BRAND NAME: FV - Area Andina SA

Certification Date	Model Name	Model Number	Product Type	Flush Type	Flushometer Rated Flush Volume (single or full) gpf	Flushometer Rated Flush Volume (Reduced Flush) gpf	Fixture Rated Flush Volume (gpf)
09/09/20	Fluxómetro para Inodoro 1 GPF (3,8 lt/descarga)	E365.22.4 CR	Flushometer Valve	Single	1.0		
09/09/20	Inodoro Quantum Luxe HET	E161	Fixture				1.0

Conditions of Listing:

1. The FV - Area Andina SA models recognized in this listing must be installed in accordance with the manufacturer's published installation instructions and the applicable code.
2. The FV - Area Andina SA models recognized in this listing are manufactured under a quality control program with annual surveillance inspections by ICC-ES.